



**SPORTON LAB.**

Certificate No: C280806

# CERTIFICATE

**EQUIPMENT** : Embedded Controller

**MODEL NO.** : I-7188XA, I-7188XAD, I-7188XB, I-7188XBD, I-7188XG, I-7188XGD,  
I-7521, I-7016P, I-7016PD, I-7022, I-7522A, I-7522AD, I-7524,  
I-7524D, I-7527, I-7527D

**APPLICANT** : ICP DAS CO., LTD.

No. 36, Lane 91, Tung Mei Rd.,  
Hsin Chu, Taiwan, R.O.C.



I HEREBY

CERTIFY THAT:

THE MEASUREMENTS SHOWN IN THIS TEST REPORT WERE MADE IN ACCORDANCE WITH THE PROCEDURES GIVEN IN **EUROPEAN COUNCIL DIRECTIVE 89/336/EEC**. THE EQUIPMENT WAS **PASSED** THE TEST PERFORMED ACCORDING TO **European Standard EN 55022:1998 Class A, EN 61000-3-2:2000, EN 61000-3-3:1995 and EN 55024:1998 ( IEC 61000-4-2:1995, IEC 61000-4-3:1995, IEC 61000-4-4:1995, IEC 61000-4-5:1995, IEC 61000-4-6:1996, IEC 61000-4-8:1993, IEC 61000-4-11:1994 )**. THE TEST WAS CARRIED OUT ON **Aug. 29, 2002 AT SPORTON INTERNATIONAL INC. LAB.**

*K. J. Lin for Sep. 13, 2002*

K. J. Lin  
Manager