

Test Report Certification

Quietek Corporation

No.75-1, Wang-Yeh Valley, Yung-Hsing, Chiung-Lin,

Hsin-Chu County, Taiwan, R.O.C.

Tel : 886-3-592-8858, Fax: 886-3-592-8859

E-Mail : quietek@ms24.hinet.net

Accredited by NIST(NVLAP), VCCI, BSMI, DNV, TUV, Nemko

Applicant : ICP DAS CO., LTD.
Address : 2F, No. 526, Sec. 1, Kuang Fu Rd., Hsinchu, Taiwan, R.O.C.
Equipment Type : ICPCON 8000 Series
Model : 8811, 8411, 8054, 8068, 8052, 8060, 87053, 87057, 8051, 8056,
87054, 87063, 87068, 87052, C811, P801
Measurement Standard : EN 55022/1998 Class A, EN 61000-3-2,-3/1995, EN55024/1998
Measurement Procedure : EN 55022/1998, EN 61000-3-2,-3/1995, EN 61000-4-2/1995,
EN 61000-4-3/1996, EN 61000-4-4/1995, EN 61000-4-5/1995,
EN 61000-4-6/1996, EN 61000-4-8/1993, EN 61000-4-11/1994
Operation Voltage : 230VAC/50Hz
Test Result : Complied
Test Date : April 20, 2001
Report No. : 014H034E



The Test Results relate only to the samples tested.

The test report shall not be reproduced except in full without the written approval of Quietek Corporation.

Documented by: Rosita Lu

Test Engineer: Kuofeng Fang

Approved: Kevin Wang

Rosita Lu

Kuofeng Fang

Kevin Wang

